

महाराष्ट्र पर्यावरण अभियांत्रिकी प्रशिक्षण आणि संशोधन संस्था (मित्रा)
(महाराष्ट्र शासनाची अंगीकृत संस्था)



महसुल आयुक्त कार्यालयासमोर
आय.एस.पी.रोड,नाशिकरोड,नाशिक-४२२१०१
(महाराष्ट्र)फोन (०२५३) २४६२५१२
Email- senrtc@gmail.com
Web :- www.meetra.org.in

जा.क्र.मीत्रा/भांडार/ 1179 /२०२३ दिनांक:- 22/11/2023
दरपत्रक सूचना

विषय :- दरपत्रक सादर करणे बाबत.

मीत्रा संस्थेच्या जुने वसतीगृह इमारतीच्या मागील भागातील नादुरुस्त Electric Panel Board नवीन बसविणे.

खाली नमुद केलेल्या संचालक तथा अधीक्षक अभियंता महाराष्ट्र पर्यावरण अभियांत्रिकी प्रशिक्षण आणि संशोधन संस्था (मीत्रा) नाशिक रोड,नाशिक खालील विवरण पत्रातील कामे करण्यासाठी मोहोर बंद लिफाफ्याज दरपत्रके मागवित आहे.

सदरचे दरपत्रके या कार्यालयास दिनांक 9/9/२०२३ रोजी दुपारी १४.०० वाजेपर्यंत पोहचेल अशा बेताने सादर करावीत.उशिरा आलेले दरपत्रके स्विकारले जाणार नाहीत याची नोंद घेण्यात यावी.

कामाचे नाव:- मीत्रा संस्थेच्या जुने वसतीगृह इमारतीच्या मागील भागातील नादुरुस्त Electric Panel Board नवीन बसविणे.


Sr. No	Qty	Unit	Description	Lumsum Rate With GST
1	7.00	Kg	Al. bus bar suitable for 250 Amp.with insulator and taping with PVC colour coding	
2	6.00	No	Supplying & erecting porcelain/epoxy bus bar support complete erected in provided M.S. box for 200/300A	
			Incoming	
3	1.00	No	Providing & erecting 3 Pole MCCB 415V, 250A, rated short-circuit breaking capacity 36 kA (Ics=100% of Icu) adjustable thermal (overload) setting and adjustable magnetic setting with provided leads, provision for installation of shunt/UV/trip alarm contact and MCCB should have phase barriers both sides, with insulation withstand capacity 800V, no line-load bias in provided enclosure/panel as per specification no. SW-SWR/MCCB	
			4P MCCB 250A	
			Outgoing	

4	1.00	No	Supplying and erecting extended rotary handle for MCCB with adjustable telescopic rod suitable for up to 250A MCCB.
5	1.00	(Set of 8)	Supplying and erecting terminal spreaders suitable for 4 pole, above 100A up to 250A MCCB (Set of 8)
			Terminal spreader
6	6.00	No	Supplying, erecting & marking FPMCB 63A, with rated short - circuit breaking capacity (Icn) 10kA in provided distribution board as per specification no. SW-SWR/MCB
7	3.00	No	Supplying, erecting & marking FPMCB 32A, with rated short - circuit breaking capacity (Icn) 10kA in provided distribution board as per specification no. SW-SWR/MCB
8	3.00	No	Supplying, erecting & marking SPMCB 6A to 32A, C-series with rated short -circuit breaking capacity (Icn) 10kA in provided distribution board as per specification no. SW-SWR/MCB
			6 A SP MCB for control
9	1.00	No	Supplying and erecting self-locking arrangement with keys in duplicate, made of brass of grade 1 compliance to IS 729-1979 duly erected, flush with surface of panel / cupboard
			Self locking arrangement
10	1.00	No	Supplying and erecting panel mounting type digital voltmeter having three and half digit LED display, calibrated for 0 to 750V AC suitable to operate leads and lugs and mounting hardware on provided panel complete with calibration certificate from manufacturer.
			Volt Meter digital type 0 to 500 Volts
11	1.00	No	Supplying and erecting panel mounting type digital ammeter having three and half digit LED display, external CT operated, calibrated for suitable to operate on 500V, 0 to 1000A having accuracy class of 0.5, AC supply with necessary PVC wire leads and lugs and mounting hardware on provided panel complete with calibration certificate from manufacturer.
			Ammeter digital type
12	3.00	No	Supplying and erecting LT current transformer with bar primary 50/5 to 1000/5 ratio with 15 VA burden erected in provided CRCA box duly secured with insulating materials connected to the meter with test certificates.
			CT

13			Supplying and erecting metal work in CRCA sheet including Iron work for supports with fabrication of boxes, panel boards, etc. including cutting, bending, drilling, welding, riveting, treated with anti-rust treatment and duly powder coated or painted with one coat of red lead paint and 2 coats of enamel paint complete.
	62.00	Kg	M. S. Fabrication in 14 SWG @ front & Bottom (15.7 Kg/ Sq meter) 16 SWG @ Other sides (12.55 Kg/ Sq meter) Size-1.2 x 1 x 0.30
14	2.00	Kg	Supplying and erecting iron work, sheet metal work consisting of CRCA sheets, various sections of iron, plates, chequered plates, rods, bars, MS pipes, etc. for panel board or any other purpose with bending, cutting, drilling and welding complete erected at the switchgears or as per directions by the authority. painted with one coat of red oxide and two coats of enamel paint to match the position with necessary materials duly
			M.S. Channel/angle work
15	2.00	No	Supplying and erecting selector switch suitable for voltmeter/ammeter for 3 phase AC supply 500V, 50Hz, on provided box / panel and duly connecting with necessary PVC wire leads and lugs.
			Selector switches
16	3.00	No	Supplying & erecting LED type indicating pilot lamp with LED colours red / yellow / green, 230 / 250V on provided box / panel with necessary material, wiring & connections etc.
			Pilot lamp set
17	1.00	Each	Supplying and erecting GI sheet of 1.25mm (18 SWG) size 200 x 150 mm duly painted with red oxide & enamel paint for displaying the department, date of erection of the electrical installation with approved shade complete.
			Danger board
18	1.00	job	Internal Wiring & Installation
19	1.00	No	Dismantling existing OCB, ACB, MCCB, VCB complete from existing panel board in an approved manner
20	1.00	No	Dismantling any type of unserviceable feeder pillar, switch gear panel, capacitor panel, metering panel, bus-bar panel, electronic equipment panel, etc. and making the site as required, Approx. size (up to 200cm. x 90 cm x 45 cm and above) - Big Cupboard
Total Amount			

अटी व शर्ती :-

१. दरपत्रकासोबत पॅनकार्ड, आधार कार्ड, GST प्रमाणपत्र Shop Act.नुसार नोंदणी प्रत सादर करावी.
२. दरपत्रक सादर करणा-या अभिकरणाने विद्युत काम करण्याबाबत असलेले नोंदणी प्रमाणपत्र सादर करणे बंधनकारक आहे.
३. अभिकरणाकडे वरील प्रकारचे कामाचे साम्य असलेले काम केल्याबाबतचे अनुभव असलेल्या प्रमाणपत्रांच्या छायांकीत प्रती सादर कराव्यात.
४. दर पत्रके एजन्सीच्या लेटरहेडवर स्वतःच्या स्वाक्षरी आणि शिक्क्यासह सर्वप्रकारच्या करासहीत सर्व समावेशक दर नमुद करुन मोहोर बंद पाकीटातच भरावेत.सदर दर हे GST सह आहेत असे समजण्यात येईल.त्याव्यतिरीक्त कोणत्याही प्रकारचे अतिरीक्त आकार,शुल्क,सर्व्हिस चार्जेस इ.आदाकेले जाणार नाहीत.
५. कार्यादेश दिल्यानंतर प्रथम काम पूर्ण करावे लागेल त्यानंतर त्याचे देयक सादर केल्यानंतर सदर देयकाची पडताळणी करुन नियमानुसार शासकीय वजावती केल्यानंतर देयक धनादेश/आर.टी.जी.एस.व्दारे आदा करण्यात येईल.
६. दरपत्रक दि. १ /१२/२०२३ रोजी दु.४.००वाजेपर्यंत स्विकारण्यात येतील. दर पत्रके सदर विहित वेळेतच कार्यालयात सादर करावेत अन्यथा वेळनंतर आलेले दर पत्रके स्विकारले जाणार नाहीत याची कृपया नोंद घ्यावी हि विनंती.
७. निम्न स्वाक्षरी धारकानी दर पत्रके मंजूर अथवा रद्द करण्याचे अधिकार स्वतःकडे राखुन ठेवण्यात आलेले आहेत.


(सौ.सुनंदा नरवाडे)
संचालक (प्रशासन)
मीत्रा नाशिक

प्रत:- नोटीस बोर्ड मीत्रा कार्यालय नाशिक येथे लावण्यासाठी.